

APPROVAL OF SERVICE SUPPLIERS

Certificate No: AOSS0000EFH Revision No:

This is to certify that

Brandab Skydd & Säkerhet AB

KARLSKRONA, Sweden

is granted acceptance for

Inspection and maintenance of fire extinguishing equipment and systems. Inspections and maintenance of self-contained breathing apparatus. In accordance with Class Programmes DNV-CP-0484 and DNV-CP-0624, and IACS UR Z17 Annex 1[7].

This service supplier certificate will be accepted for use with all rule sets published by DNV. See the following page(s) for details regarding application.

This Certificate is valid from 2024-03-21 to (inclusive) 2027-03-20.

This Certificate is issued on 2024-02-20.



for **DNV**

This document has been digitally signed and will therefore not have handwritten signatures

> Højmann, Jørgen Surveyor

This Certificate may be withdrawn if:

- 1. The service provided has been improperly carried out or the results improperly reported.
- 2. The surveyor has found any deficiencies in the accepted operating systems of the service supplier.
- The firm has failed to inform of any major changes having effect on the quality of the service rendered.
 The conditions listed in the certificate are changed and/or are not fulfilled.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: AOSS 101 Revision: 2022-12 Page 1 of 2



Certificate No: AOSS0000EFH

Revision No: 2

Application:

This approval is granted for:

- CO2 High Pressure, fixed fire-fighting systems
- Halon, fixed fire-fighting systems
- Foam, portable fire-fighting systems
- Dry Powder, fixed fire-fighting systems
- Inergen, fixed fire-fighting systems
- Halotron, fixed fire-fighting systems
- Novec, fixed fire-fighting systems
- Argonite, fixed fire-fighting systems
- FM200, fixed fire-fighting systems
- Firepro, fixed fire-fighting systems
- Portable fire extinguishers
- Hydrostatic testing and testing of pressure vessels/bottles

Remarks:

Foam analysis is carried out at Dafo Fomtec AB.

Form code: AOSS 101 Revision: 2022-12 www.dnv.com Page 2 of 2